

ADDENDUM NO. 1

Dated: February 29, 2024

Plans and Specifications for: **8th Street Pavement and Utility Replacement from Burleigh Street to Ferdig Street**

Bids Due: 3:00 PM
March 14, 2024
City Finance Officer
P.O. Box 176
Yankton, SD 57078

Contact Person: Bradley Moser
Civil Engineer
P.O. Box 176
Yankton, SD 57078
(605) 668-5255

The original plans and specifications are hereby amended by this Addendum. Bidders shall acknowledge receipt of this addendum by noting the addendum number and date on the space provided on the Bid Form. Bidders who distribute these specifications to subcontractors or suppliers are responsible for the distribution of the information contained herein to either the subcontractor or supplier.

Issued By *Bradley C Moser*
Bradley C. Moser, Civil Engineer

1. The following revisions have been made to the original contract documents. All 12" RCP should be Class 5. All 18" and 24" RCP should be Class 3. These changes should be reflected in your bid. The quantities for each item have not changed. The attached Page 4 of the Bid Proposal section must be utilized when submitting your bid.