

**ADDENDUM NO. 2**

Dated: March 11, 2024

Plans and Specifications for: **21<sup>st</sup> Street Reconstruction from West City Limits Road to Summit Street**

Bids Due: 3:00 PM  
March 14, 2024  
City Finance Officer  
P.O. Box 176  
Yankton, SD 57078

Contact Person: Bradley Moser  
Civil Engineer  
P.O. Box 176  
Yankton, SD 57078  
(605) 668-5255

The original plans and specifications are hereby amended by this Addendum. Bidders shall acknowledge receipt of this addendum by noting the addendum number and date on the space provided on the Bid Form. Bidders who distribute these specifications to subcontractors or suppliers are responsible for the distribution of the information contained herein to either the subcontractor or supplier.

Issued By



---

Bradley C. Moser, Civil Engineer

1. Monolithic paving will be allowed on the project. Please note that the longitudinal joint, where the gutter would normally meet the paving, will still need a sawed joint with tie bars. Also, if you are planning on paving half at a time, this will require two additional longitudinal joints with tie bars to be utilized.
2. The estimated seeding quantity listed on sheet 6 of the plans should have been 26000 SF. Please utilize this quantity when figuring your Lump Sum price on the proposal form.