ADDENDUM NO. 2

Dated: May 30, 2024

Plans and Specifications for: Cedar Street – 2nd Street to 5th Street -Parking Lot and Alley **Street & Utility Improvements**

Bids Due:	3:00 PM	Contact Person:	Bradley Moser
	June 4, 2024		Civil Engineer
	City Finance Officer		P.O. Box 176
	P.O. Box 176		Yankton, SD 57078
	Yankton, SD 57078		(605) 668-5255

The original plans and specifications are hereby amended by this Addendum. Bidders shall acknowledge receipt of this addendum by noting the addendum number and date on the space provided on the Bid Form. Bidders who distribute these specifications to subcontractors or suppliers are responsible for the distribution of the information contained herein to either the subcontractor or supplier.

Issued By Bradley C. Moser, Civil Engineer

- 1. The attached Bid Proposal form changes the bid item #17 to 10" sanitary sewer pipe. This form should be utilized when submitting your bid. It should be understood that any reference, in the plans, of 8" sanitary sewer pipe replacement should actually be 10" sanitary sewer pipe.
- 2. There was a conflict between the specifications and the detail in the plans, pertaining to the manhole frame and lid. It should be a Neenah-1733 or equal.
- 3. The casting for drop inlet #4 should be Neenah R-3067 furnished without curb box and a type Q grate. This casting is used specifically for driveway locations.