

Our Water Source

We serve more than 13,703 customers an average of 2,395,000 gallons of water per day. We get our water from surface water sources. The state has performed an assessment of our source water and they have determined that the relative susceptibility rating for the Yankton public water supply system is medium.



The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.


Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

PRESORT STD
US POSTAGE
PAID
MINNEAPOLIS, MN
PERMIT # 4557

**Water Superintendent
Box 176
Yankton, SD 57078**

ECRWSS
Residential Customer Local



Last year the City of Yankton monitored your drinking water for more than 80 possible contaminants. This brochure is a snapshot of the quality of the water that we provided last year. Included are details about where your water comes from, what it contains, and how it compares to the Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies.



For more information about your water and information on opportunities to participate in public meetings, call (605) 668-5270 and ask for Kyle Goodmanson.

EPA Drinking Water Information

In order to ensure that tap water is safe to drink, the U. S. Environmental Protection Agency (EPA) prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Yankton public water supply system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing the tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

Understanding the Table

The table to the right lists all the drinking water contaminants that we detected during the 2009 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1- December 31, 2009. The state requires us to monitor for certain contaminants less than once per year because concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. **MCLGs** allow for a margin of safety. **Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. **MCLs** are set as close to the **MCLGs** as feasible using the best available treatment technology. **Action Level (AL):** The concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow. For lead and copper, 90% of the samples must be below the **AL**. **Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water. For turbidity, 95% of the samples must be less than 0.3 NTU. **Removal Ratio (RR):** The TOC removal ratio is the ratio between the actual TOC removal and the TOC removal requirements. The lowest running annual average of quarterly percentages is reported. **Units:** **NTU:** Nephelometric Turbidity Units. **N/A:** Not Applicable. **ND:** No detection. **ppm:** Parts per million. **ppb:** Parts per billion.

2009 Yankton Water Testing Results

Violation Type	Parameter	Violation Date	Health Effects	Action Taken by Yankton
Exceedance of Allowable Contaminant Level	Trihalomethane (THM)	1/1/2009	Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer.	We are now back in compliance as of March 31, 2009.

Contaminant (unit)	Level Detected	Range	Date Tested	MCL	MCLG	Source of Contaminant
2,4,5-TP (Silvex) (ppb)	2	0 - 2	5/24/06	50	50	Residue of banned herbicide.
Barium (ppm)	0.013	—	10/26/09	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Chromium (ppb)	0.5	—	10/26/09	100	100	Discharge from steel and pulp mills; Erosion of natural deposits.
Copper (ppm)	90% Level: 0	Test Sites > Action Level: 0	8/7/09	AL = 1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives.
Fluoride (ppm)	1.29	1.11 - 1.29	6/8/09	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Haloacetic Acids (ppb)	25.8	ND - 25.8	3/9/09	60	0	By-product of drinking water chlorination.
Lead (ppb)	90% Level: 0	Test Sites > Action Level: 0	8/14/09	AL = 15	0	Corrosion of household plumbing systems; Erosion of natural deposits.
Nitrate (as Nitrogen) (ppm)	0.5	—	3/9/09	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Pentachlorophenol (ppb)	7	0 - 7	5/24/06	1	0	Discharge from wood preserving factories.
Selenium (ppb)	1.8	—	10/26/09	50	50	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines.
Total Organic Carbon	1.79	1.79 - 1.93		RR	N/A	Naturally present in the environment.
Total Trihalomethanes (ppb)	101	ND - 101	9/2/09	80	0	By-product of drinking water chlorination.
Turbidity (NTU)	0.39	97% Samples < 0.3	11/1/09	TT	N/A	Soil runoff. Turbidity is a measure of clarity of the water.

